



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Report No.: Raj/DW(Chem)/2026-27/ 964-265

Dated: 30/6/26

Issued To,

The sample was not collected
by this laboratory

Principal
Oasis Public School, Chomu
Jaipur

District: Jaipur
Block/City: Chomu

Not Valid for Water
Quality Legal Cases

Ref_ID :	6	Lab Sample No. :	7
Reference : Your Letter No.:	1695	Source :	Treated Water
Reference Dated :	25-06-2026	Source Location :	RO, In Campus of Oasis Public School
Date of Receipt :	25-06-2026	Habitation/Ward No. :	Hadota
Name of Sample Taker :	Manish Saini	Village/Colony/Town :	Hadota
Desig. of Sample Taker :	Lecturer	Gram Panchayat/City Area :	Hadota
Latitude :		Date of Collection :	25-06-2026
Longitude :		Date of Examination :	29-06-2026
IS-10500:2012			
Test Parameters	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	Test Values of Samples
1 pH	6.5 to 8.5	No Relaxation	7.8
2 Turbidity(NTU)	1	5	Clear
3 Colour (Hazen Unit)	5	15	None
4 Odour	Unobjectionable	-	UO
5 Total Alkalinity (as CaCO ₃)	200	600	60
6 Total Hardness (as CaCO ₃)	300	600	70
7 Calcium (as Ca++)	75	200	12
8 Magnesium (as Mg++)	30	100	10
9 Chloride (as Cl)	600	1000	40
10 Sulphate (as SO ₄ ⁻²)	200	400	4
11 Nitrates (as NO ₃ ⁻)	45	No Relaxation	4
12 Fluoride (as F)	1.0	1.50	0.10
13 Total Dissolved Solids	500	2000	195
14 Residual Chlorine	0.2	0.5	Nil

Note:- Report is not valid for Food Licence or any Certificate.

Superintending Chemist
PHED, Lab, Jaipur

Report No.: Raj/DW(Chem)/2026-27/

Copy to:

Dated:

1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

Superintending Chemist